

# Grid Development Plan 2030 (2019), second draft




NETZ  
ENTWICKLUNGS  
PLAN **STROM**



# General



NETZ  
ENTWICKLUNGS  
PLAN **STROM**



# Grid Development Plan 2030 (2019)

## The Grid Development Plan ...




- ... is the grid development plan for the **onshore transmission grid**.
- ... constitutes a plan for the **offshore grid connections** together with the FEP and area development plans of the relevant states.
- ... takes into account the **integration of renewable energy sources** and the **development of the European energy market**.
- ... describes measures that satisfy both **legal requirements** and the **underlying scenario framework from the Federal Network Agency**.
- ... highlights **transmission requirements between start and end points** (two grid nodes) – but **does not show specific corridors or routes**.
- ... indicates measures with priority placed on optimisation over grid development, and expansion (**NOVA**).
- ... shows the expansion of the **380 kV alternating current grid** as well as **high voltage direct current (HVDC) connections** are needed to meet north-south transmission requirements.
- ... **does not show any potential power station sites** or preferred locations for renewable energy.

# Grid Development Plan 2030 (2019)

## The GDP process



NETZ  
ENTWICKLUNGS  
PLAN STROM





# Grid Development Plan 2030 (2019)

## Timeline – Where we stand



### **GDP and O-GDP 2030 (2017)**

- 22.12.2017 – Approval of the GDP 2030 (2017)
- 22.12.2017 – Approval of the O-GDP 2030 (2017)


### **GDP 2030 (2019)**

- 30.1.2018 – Submission of the Draft Scenario Framework by the TSOs
- 15.6.2018 – Approval of the Scenario Framework by the Federal Network Agency (BNetzA)
- 4.2.2019 – Publication of the first draft of the GDP 2030 (2019) by the TSOs
- 4.2. – 4.3.2019 – Public consultation period for the first draft
- 15.4.2019 – Publication of second draft by the TSOs and handover to the BNetzA
- subsequent review and second public consultation by the BNetzA
- End of 2019: approval by the BNetzA (target deadline of the German Energy Industry Act)



# Grid Development Plan 2030 (2019)


## Overview of the consultation process





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Consultation of the first draft GDP 2030 (2019)



# Consultation first draft GDP 2030 (2019)

## Overview



NETZ  
ENTWICKLUNGS  
PLAN STROM

- The first draft of the GDP 2030 (2019) was published by the TSOs on **4.2.2019** with a public consultation period from **4.2. to 4.3.2019**.
- In total **906 statements** were submitted during this period.
- **763 statements** were submitted by **individuals**.  
**143 statements** were submitted by **institutions**.
- All **electronically submitted statements**, are published at <https://www.netzentwicklungsplan.de/de/konsultation-zum-nep-2030-2019/stellungnahmen-nep-2030-2019> (**764 statements**) if the authors approved the publication.
- An individual confirmation or answer to each statement is not given.



# Consultation first draft GDP 2030 (2019)

## Incorporation of consultation statements



NETZ  
ENTWICKLUNGS  
PLAN STROM

- The TSOs considered the contents of the submitted statements and revised the first draft of the GDP 2030 (2019) on this basis.
- Each chapter of the second draft contains a **box with a summary** of the main aspects of the consultation concerning it as well as the changes to the chapter.
- Changes to the first draft of GDP are marked *in italics*.
- The consultation statements are further discussed in a separate **consultation chapter (chapter 7)**







# Consultation first draft GDP 2030 (2019)

## Statements by channel of submission



NETZ  
ENTWICKLUNGS  
PLAN **STROM**



-  Konsultationsmaske (105)
-  per E-Mail (736)
-  per Post (65)

Quelle: Übertragungsnetzbetreiber



# Consultation first draft GDP 2030 (2019)

## Statements by type of stakeholder



NETZ  
ENTWICKLUNGS  
PLAN STROM

Absender	Anzahl der Stellungnahmen
Privatpersonen	763
Kommunen	69
Bürgerinitiativen	22
Bund / Länder	15
Energieunternehmen	12
Verbände	11
Umwelt- / Naturschutzverbände	7
Sonstige	4
Unternehmen	2
Wissenschaft und Forschung	1

Compared to the GDP 2030 (2017) with 2133 statements, the number of consultation submissions for the GDP 2030 (2019) **declined by 57%**.

The decline in the number of statements concerns all stakeholder-groups.

The number of serial-letters also decreased significantly.



Quelle: Übertragungsnetzbetreiber



# Consultation first draft GDP 2030 (2019)

## Main topics



- **Basic questions and doubts** about the **assumptions** of the **scenarios**, for example compatibility with the goals of the **Paris Agreement**, the recommendations of the **Commission for Growth, Structural Change and Employment** concerning the exit from coal-fired energy production.
- The results of the **market simulation** and the resulting **requirements for grid expansion** including **the consideration of innovative technologies**.
- Regional concerns, in particular:
  - between Mecklar and Bergrheinfeld/West (P43/P43mod)
  - between Altenfeld and Grafenrheinfeld (P44/P44mod)
  - between Raitersaich, Ludersheim und Altheim (P53)as well as the three large HVDC-connections
  - from North Rhine Westphalia to Baden-Württemberg (DC2)
  - from Schleswig-Holstein to Bavaria and Baden-Württemberg (DC3/DC4)
  - From Saxony-Anhalt to Bavaria (DC5 with DC20)

# Consultation first draft GDP 2030 (2019)


## Statements on specific projects



NETZ  
ENTWICKLUNGS  
PLAN STROM

The majority of statements by individuals concern **specific projects**.


The focus of the majority of statements on a few projects lead to **680 statements** concerning projects in the control area of TenneT, almost **75%** of all statements submitted. From those statements, the majority was from **Bavaria**.





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Scenario Framework



# Grid Development Plan 2030 (2019)

## Key elements of the approved Scenario Framework




- Takes into account the expansion target for renewables from the coalition agreement from March 2018 of **65% renewables by 2030**
- Takes into account **flow based market coupling** as well as minimal **transfer capacities for interconnectors** in line with European planning procedures
- **Cost benefit analyses** for additional interconnectors
- Explicit CO<sub>2</sub> limits for power-generation in all scenarios in line with the **federal climate protection plan 2050** and coordinated with the UBA
- **Peak capping** of max. 3% of the total annual amount of onshore wind energy and solar in all scenarios as **planning instrument**
- Ambitious assumptions for **sector coupling** (E-mobility, heat pumps), **flexibility** (PtX, DSM) and **storage** (central and decentral) – increasing from scenario A to C → **Grid Development Plan in line with the current discussion**
- Calculation of **five scenarios**:
  - Short-term scenario B2025: Ad-hoc-measures / Redispatch prevention
  - Target-scenarios A 2030, B 2030, C 2030
  - Long-term scenario B 2035: sustainability check for the identified measures

# Grid Development Plan 2030 (2019)

## Classifying the scenarios



NETZ  
ENTWICKLUNGS  
PLAN STROM



Quelle: Bundesnetzagentur: Genehmigung des Szenariorahmens 2019 – 2030

→ The scenarios no longer differ in the overall speed of transformation, but only in the assumed innovations (sector-coupling, flexibility, and storage) as well as the share of the different renewable technologies.

# Grid Development Plan 2030 (2019)

## Conventional generation capacities



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Installiert (GW)	Referenz 2017	B 2025	A 2030	B 2030	C 2030	B 2035
Kernenergie	9,5	0,0	0,0	0,0	0,0	0,0
Braunkohle	21,2	9,4	9,4	9,3	9,0	9,0
Steinkohle	25,0	13,5	13,5	9,8	8,1	8,1
Erdgas	29,6	32,5	32,8	35,2	33,4	36,9
Öl	4,4	1,3	1,3	1,2	0,9	0,9
Pumpspeicher	9,5	11,6	11,6	11,6	11,6	11,8
sonstige konv. Erzeugung* <sup>1</sup>	4,3	4,1	4,1	4,1	4,1	4,1
Kapazitätsreserve	0,0	2,0	2,0	2,0	2,0	2,0
<b>Summe konv. Erzeugung*<sup>2</sup></b>	<b>103,5</b>	<b>74,4</b>	<b>74,7</b>	<b>73,2</b>	<b>69,1</b>	<b>72,8</b>

# Grid Development Plan 2030 (2019)

## Renewable generation capacities



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Installiert (GW)	Referenz 2017	B 2025	A 2030	B 2030	C 2030	B 2035
Wind onshore	50,5	70,5	74,3	81,5	85,5	90,8
Wind offshore	5,4	10,8	20,0	17,0	17,0	23,2
Photovoltaik	42,4	73,3	72,9	91,3	104,5	97,4
Biomasse	7,6	7,3	6,0	6,0	6,0	4,6
Wasserkraft* <sup>3</sup>	5,6	5,6	5,6	5,6	5,6	5,6
sonstige reg. Erzeugung* <sup>4</sup>	1,3	1,3	1,3	1,3	1,3	1,3
<b>Summe reg. Erzeugung</b>	<b>112,8</b>	<b>168,8</b>	<b>180,1</b>	<b>202,7</b>	<b>219,9</b>	<b>222,9</b>



# Grid Development Plan 2030 (2019)

## Overview of all scenarios



NETZ  
ENTWICKLUNGS  
PLAN STROM

	A 2030	B 2030	C 2030	B 2035
Conventional power stations	74.7 GW (22.9 GW Coal)	73.2 GW (19.1 GW coal)	69.1 GW (17.1 GW coal)	72.8 GW (17.1 GW coal)
Installed capacities of Renewable energy	<b>180 GW (+40 GW)</b> <b>20 GW Offshore</b> 74 GW Onshore 73 GW PV	<b>203 GW (+50 GW)</b> 17 GW Offshore 82 GW Onshore 91 GW PV	<b>220 GW (+50 GW)</b> 17 GW Offshore 86 GW Onshore <b>105 GW PV</b>	<b>223 GW</b> 23,2 GW Offshore 91 GW Onshore 97 GW PV
Net energy consumption	512 TWh	544 TWh	<b>577 TWh</b>	549 TWh
Peak-capping (wind and solar)	yes	yes	yes	yes
Sector-Coupling	moderate	high	<b>Very high</b>	high
Amount of flexibility options and storage	moderate	high	<b>Very high</b>	high
Collective power plant emission limit	184 Mio. t CO <sub>2</sub>	184 Mio. t CO <sub>2</sub>	184 Mio. t CO <sub>2</sub>	127 Mio. t CO <sub>2</sub>


# Grid Development Plan 2030 (2019)

## Overview of the distribution of installed capacity per energy source in the four scenarios of the GDP 2030




NETZ  
ENTWICKLUNGS  
PLAN STROM

Referenz 2017



B 2025



konventionelle Erzeugung




regenerative Erzeugung




\*sonstige konv. Erzeugung zuzüglich 50 % Abfall | \*\*Speicherwasser, Laufwasser | \*\*\*sonstige reg. Erzeugung zuzüglich 50 % Abfall


A 2030




B 2030



C 2030



B 2035



# Grid Development Plan 2030 (2019)

## Results of renewable peak capping



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Szenario	Eingesenkte Einspeisemenge Onshore-Windenergie (TWh)	Eingesenkte Einspeisemenge Photovoltaik (TWh)
<b>B 2025</b>	2,6	0,8
<b>A 2030</b>	2,8	0,8
<b>B 2030</b>	3,1	1,0
<b>C 2030</b>	3,2	1,1
<b>B 2035</b>	3,4	1,0


Capped amounts of onshore wind and PV

# Grid Development Plan 2030 (2019)

## Peak capping of onshore wind energy by state



NETZ  
ENTWICKLUNGS  
PLAN STROM



Quelle: Übertragungsnetzbetreiber


# Grid Development Plan 2030 (2019)

## Change of electricity demand by municipality including sector-coupling and PtG/PtH




NETZ  
ENTWICKLUNGS  
PLAN STROM

- **Increasing demand** in urban regions and neighboring conurbations
- **Decreasing demand** in most municipalities in eastern Germany and rural regions.
- **Main factors** determining regional demand are **population** as well as **E-mobility**, **heat pumps** and **PtG- and PtH-facilities**.







Power-to-Heat – B 2025




Power-to-Heat – A 2030




Power-to-Heat – B 2030




Power-to-Heat – C 2030



Power-to-Heat – B 2035



Power-to-Heat in MW



## Regional use of flexibility- options: Power-to-heat facilities

Quelle: Übertragungsnetzbetreiber

Assumed regional distribution of power-to-heat facilities in Germany


# Grid Development Plan 2030 (2019)

## Full load hours by scenario



NETZ  
ENTWICKLUNGS  
PLAN STROM

Abbildung 46: Vergleich der Volllaststunden je Szenario des NEP 2030 (2019)





# Grid Development Plan 2030 (2019)


## Installed capacity by state

### Scenario B 2025



NETZ  
ENTWICKLUNGS  
PLAN STROM

B 2025 (in GW)	Braun- kohle	Stein- kohle	Erdgas	Kuppel- gas	Öl	Abfall	Pump- speicher	KWK < 10 MW	sonstige Konven- tionelle	Wind onshore	Wind offshore	Photo- voltaik	Bio- masse	Lauf- und Speicher- wasser	sonstige EE	Band der Nachfrage	zusätzliche Verbraucher		
																	DSM	PtG	PlH
BW	0,0	2,8	1,9	0,0	0,1	0,1	1,9	1,0	0,0	2,6	0,0	10,4	0,8	1,0	0,0	4,1 – 11,9	0,3	0,0	0,5
BY	0,0	0,5	4,9	0,0	0,0	0,2	0,8	0,9	0,0	2,6	0,0	17,5	1,5	2,4	0,1	5,1 – 14,2	0,4	0,0	0,5
BE	0,0	0,7	1,0	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,5	0,0	0,0	0,0	0,9 – 2,5	0,1	0,0	0,2
BB	1,6	0,0	0,5	0,1	0,3	0,1	0,0	0,3	0,0	8,7	0,0	5,1	0,5	0,0	0,0	1,1 – 2,9	0,1	0,0	0,1
HB	0,0	0,1	0,5	0,2	0,0	0,1	0,0	0,1	0,0	0,5	0,0	0,2	0,0	0,0	0,0	0,3 – 0,8	0,0	0,0	0,2
HH	0,0	1,8	0,2	0,0	0,0	0,0	0,0	0,2	0,0	0,1	0,0	0,2	0,1	0,0	0,0	0,9 – 2,0	0,1	0,0	0,2
HE	0,0	0,7	1,6	0,0	0,0	0,1	0,6	0,5	0,0	3,3	0,0	3,8	0,3	0,1	0,0	2,4 – 6,2	0,2	0,0	0,1
MV	0,0	0,5	0,3	0,0	0,0	0,0	0,0	0,2	0,0	5,0	1,8	3,2	0,3	0,0	0,0	0,5 – 1,3	0,0	0,0	0,4
NI	0,0	1,2	2,4	0,3	0,0	0,1	0,2	0,7	0,0	14,3	6,9	6,6	1,4	0,1	0,0	3,4 – 8,7	0,4	0,1	0,8
NW	3,3	5,0	8,8	1,3	0,2	0,5	0,3	1,3	0,2	8,4	0,0	9,8	0,9	0,2	0,4	8,7 – 21,1	0,8	0,1	1,3
RP	0,0	0,0	1,8	0,0	0,0	0,1	0,0	0,3	0,0	5,2	0,0	3,8	0,2	0,2	0,0	2,0 – 4,4	0,2	0,0	0,1
SL	0,0	0,3	0,2	0,1	0,0	0,0	0,0	0,1	0,0	0,4	0,0	0,9	0,0	0,0	0,1	0,5 – 1,5	0,1	0,0	0,1
SN	3,4	0,0	0,8	0,0	0,0	0,0	1,1	0,4	0,0	1,8	0,0	3,1	0,3	0,1	0,0	1,4 – 3,6	0,1	0,0	0,1
ST	1,0	0,0	0,8	0,0	0,2	0,2	0,1	0,3	0,0	6,4	0,0	3,4	0,5	0,0	0,0	1,0 – 2,5	0,1	0,1	0,1
SH	0,0	0,1	0,5	0,0	0,0	0,0	0,1	0,3	0,1	9,0	2,1	2,8	0,5	0,0	0,0	0,9 – 2,7	0,1	0,0	1,0
TH	0,0	0,0	0,5	0,0	0,0	0,0	3,0	0,3	0,0	2,2	0,0	2,0	0,3	0,0	0,0	0,8 – 2,2	0,1	0,0	0,1
AT (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,6	0,0	0,0	0,0	0,0	0,0	0,0	0,8	0,0	0,0 – 0,0	0,0	0,0	0,0
LU (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0 – 0,0	0,0	0,0	0,0
Summe**	9,4	13,5	26,5	2,0	0,9	1,7	11,0	6,8	0,4	70,5	10,8	73,3	7,6	5,1	0,6	34,4 – 88,2	3,0	0,5	5,8



\* Erzeugungsanlagen im Ausland mit Einspeisung in das deutsche Übertragungsnetz  
 \*\* Bei der Aufsummierung der Einzelwerte können sich Rundungsabweichungen ergeben.  
 \*\*\* Das Band der Nachfrage umfasst den klassischen Stromverbrauch sowie Wärmepumpen, Elektromobilität und VNB-Verluste ohne Einsatz von DSM, Power-to-Gas / -Heat.



# Grid Development Plan 2030 (2019)

## Installed capacity by state

### Scenario A 2030




NETZ  
ENTWICKLUNGS  
PLAN STROM

A 2030 (in GW)	Braun- kohle	Stein- kohle	Erdgas	Kuppel- gas	Öl	Abfall	Pump- speicher	KWK < 10 MW	sonstige Konven- tionelle	Wind onshore	Wind offshore	Photo- voltaik	Bio- masse	Lauf- und Speicher- wasser	sonstige EE	Band der Nachfrage	zusätzliche Verbraucher		
																	DSM	PtG	PtH
BW	0,0	2,8	1,0	0,0	0,1	0,1	1,9	1,1	0,0	2,8	0,0	9,6	0,7	1,0	0,0	4,0 – 11,5	0,2	0,0	0,2
BY	0,0	0,5	3,9	0,0	0,0	0,2	0,8	1,1	0,0	2,6	0,0	17,9	1,2	2,4	0,1	5,0 – 13,6	0,3	0,1	0,1
BE	0,0	0,7	1,1	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,4	0,0	0,0	0,0	0,8 – 2,4	0,0	0,0	0,1
BB	1,6	0,0	0,6	0,1	0,3	0,1	0,0	0,4	0,0	9,3	0,0	6,3	0,4	0,0	0,0	1,1 – 2,7	0,1	0,1	0,0
HB	0,0	0,1	0,5	0,2	0,0	0,1	0,0	0,1	0,0	0,5	0,0	0,2	0,0	0,0	0,0	0,3 – 0,8	0,0	0,0	0,2
HH	0,0	1,8	0,2	0,0	0,0	0,0	0,0	0,3	0,0	0,1	0,0	0,2	0,0	0,0	0,0	0,9 – 2,0	0,1	0,0	0,2
HE	0,0	0,7	1,0	0,0	0,0	0,1	0,6	0,6	0,0	3,4	0,0	3,3	0,2	0,1	0,0	2,3 – 5,9	0,1	0,0	0,0
MV	0,0	0,5	0,3	0,0	0,0	0,0	0,0	0,2	0,0	5,4	2,2	4,5	0,3	0,0	0,0	0,4 – 1,2	0,0	0,0	0,3
NI	0,0	1,2	2,6	0,3	0,0	0,1	0,2	0,8	0,0	15,4	13,8	5,9	1,1	0,1	0,0	3,3 – 8,3	0,2	0,2	0,5
NW	3,3	5,0	9,5	1,3	0,2	0,5	0,3	1,5	0,2	8,6	0,0	8,5	0,7	0,2	0,4	8,5 – 20,2	0,6	0,3	0,0
RP	0,0	0,0	1,9	0,0	0,0	0,1	0,0	0,4	0,0	5,3	0,0	3,7	0,1	0,2	0,0	1,9 – 4,2	0,1	0,1	0,0
SL	0,0	0,3	0,2	0,1	0,0	0,0	0,0	0,1	0,0	0,4	0,0	0,8	0,0	0,0	0,1	0,5 – 1,5	0,0	0,0	0,0
SN	3,4	0,0	0,8	0,0	0,0	0,0	1,1	0,5	0,0	1,8	0,0	3,1	0,3	0,1	0,0	1,4 – 3,4	0,1	0,1	0,0
ST	1,0	0,0	0,8	0,0	0,2	0,2	0,1	0,4	0,0	6,6	0,0	3,8	0,4	0,0	0,0	1,0 – 2,3	0,1	0,1	0,0
SH	0,0	0,1	0,6	0,0	0,0	0,0	0,1	0,3	0,1	9,6	4,0	2,9	0,4	0,0	0,0	0,8 – 2,6	0,1	0,1	0,7
TH	0,0	0,0	0,5	0,0	0,0	0,0	3,0	0,3	0,0	2,4	0,0	2,0	0,2	0,0	0,0	0,7 – 2,0	0,0	0,0	0,0
AT (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,6	0,0	0,0	0,0	0,0	0,0	0,0	0,8	0,0	0,0 – 0,0	0,0	0,0	0,0
LU (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0 – 0,0	0,0	0,0	0,0
Summe**	9,4	13,5	25,5	2,0	0,9	1,7	11,0	8,3	0,4	74,3	20,0	72,9	6,0	5,1	0,6	33,5 – 84,4	2,0	1,0	2,5



/// Band der Nachfrage (ungleichzeitig)\*\*\*



\* Erzeugungsanlagen im Ausland mit Einspeisung in das deutsche Übertragungsnetz

\*\* Bei der Aufsummierung der Einzelwerte können sich Rundungsabweichungen ergeben.

\*\*\* Das Band der Nachfrage umfasst den klassischen Stromverbrauch sowie Wärmepumpen, Elektromobilität und VNB-Verluste ohne Einsatz von DSM, Power-to-Gas / -Heat.

# Grid Development Plan 2030 (2019)


## Installed capacity by state

### Scenario B 2030



NETZ  
ENTWICKLUNGS  
PLAN STROM

B 2030 (in GW)	Braun- kohle	Stein- kohle	Erdgas	Kuppel- gas	Öl	Abfall	Pump- speicher	KWK < 10 MW	sonstige Konven- tionelle	Wind onshore	Wind offshore	Photo- voltaik	Bio- masse	Lauf- und Speicher- wasser	sonstige EE	Band der Nachfrage	zusätzliche Verbraucher		
																	DSM	PtG	PtH
BW	0,0	2,7	1,9	0,0	0,1	0,1	1,9	1,1	0,0	3,2	0,0	12,5	0,7	1,0	0,0	4,1 – 12,8	0,4	0,0	0,8
BY	0,0	0,0	4,9	0,0	0,0	0,2	0,8	1,1	0,0	2,6	0,0	20,7	1,2	2,4	0,1	5,2 – 15,2	0,5	0,1	0,8
BE	0,0	0,0	1,4	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	0,7	0,0	0,0	0,0	0,9 – 2,6	0,1	0,0	0,6
BB	1,6	0,0	0,5	0,1	0,3	0,1	0,0	0,4	0,0	10,0	0,0	6,5	0,4	0,0	0,0	1,1 – 3,0	0,1	0,1	0,2
HB	0,0	0,1	0,5	0,2	0,0	0,1	0,0	0,1	0,0	0,5	0,0	0,3	0,0	0,0	0,0	0,3 – 0,8	0,0	0,0	0,3
HH	0,0	1,8	0,2	0,0	0,0	0,0	0,0	0,3	0,0	0,1	0,0	0,4	0,0	0,0	0,0	0,9 – 2,1	0,1	0,0	0,3
HE	0,0	0,5	1,8	0,0	0,0	0,1	0,6	0,6	0,0	3,6	0,0	4,9	0,2	0,1	0,0	2,4 – 6,6	0,2	0,0	0,4
MV	0,0	0,5	0,3	0,0	0,0	0,0	0,0	0,2	0,0	6,3	2,3	4,4	0,3	0,0	0,0	0,5 – 1,4	0,0	0,1	0,5
NI	0,0	0,9	2,6	0,3	0,0	0,1	0,2	0,8	0,0	17,1	10,8	8,4	1,1	0,1	0,0	3,4 – 9,3	0,5	0,3	1,1
NW	3,3	3,3	9,0	1,3	0,2	0,5	0,3	1,5	0,2	9,2	0,0	12,7	0,7	0,2	0,4	8,6 – 22,0	1,1	0,6	2,0
RP	0,0	0,0	1,8	0,0	0,0	0,1	0,0	0,4	0,0	5,7	0,0	4,8	0,1	0,2	0,0	2,0 – 4,7	0,2	0,1	0,2
SL	0,0	0,0	0,3	0,1	0,0	0,0	0,0	0,1	0,0	0,4	0,0	1,1	0,0	0,0	0,1	0,5 – 1,6	0,1	0,0	0,2
SN	3,3	0,0	0,9	0,0	0,0	0,0	1,1	0,5	0,0	1,8	0,0	3,8	0,3	0,1	0,0	1,4 – 3,7	0,1	0,1	0,3
ST	1,0	0,0	0,8	0,0	0,2	0,2	0,1	0,4	0,0	6,7	0,0	4,2	0,4	0,0	0,0	1,0 – 2,6	0,1	0,2	0,2
SH	0,0	0,0	0,5	0,0	0,0	0,0	0,1	0,3	0,1	11,3	4,0	3,6	0,4	0,0	0,0	0,9 – 3,0	0,1	0,1	1,1
TH	0,0	0,0	0,5	0,0	0,0	0,0	3,0	0,3	0,0	3,0	0,0	2,5	0,2	0,0	0,0	0,7 – 2,2	0,1	0,0	0,1
AT (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,6	0,0	0,0	0,0	0,0	0,0	0,0	0,8	0,0	0,0 – 0,0	0,0	0,0	0,0
LU (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0 – 0,0	0,0	0,0	0,0
Summe**	9,3	9,8	27,8	2,0	0,9	1,7	11,0	8,3	0,3	81,5	17,0	91,3	6,0	5,1	0,6	34,2 – 93,2	4,0	2,0	9,1



\* Erzeugungsanlagen im Ausland mit Einspeisung in das deutsche Übertragungsnetz

\*\* Bei der Aufsummierung der Einzelwerte können sich Rundungsabweichungen ergeben.

\*\*\* Das Band der Nachfrage umfasst den klassischen Stromverbrauch sowie Wärmepumpen, Elektromobilität und VNB-Verluste ohne Einsatz von DSM, Power-to-Gas / -Heat.





# Grid Development Plan 2030 (2019)


## Installed capacity by state

### Scenario B 2035



NETZ  
ENTWICKLUNGS  
PLAN STROM

B 2035 (in GW)	Braunkohle	Steinkohle	Erdgas	Kuppel- gas	Öl	Abfall	Pump- speicher	KWK < 10 MW	sonstige Konven- tionelle	Wind onshore	Wind offshore	Photo- voltaik	Bio- masse	Lauf- und Speicher- wasser	sonstige EE	Band der Nachfrage	zusätzliche Verbraucher		
																	DSM	PtG	PtH
BW	0,0	2,3	2,1	0,0	0,0	0,1	2,1	1,3	0,0	4,6	0,0	13,0	0,5	1,0	0,0	4,1 – 13,1	0,6	0,0	1,1
BY	0,0	0,0	4,9	0,0	0,0	0,2	0,8	1,3	0,0	2,6	0,0	22,0	0,9	2,4	0,1	5,2 – 15,6	0,7	0,2	1,2
BE	0,0	0,0	1,4	0,0	0,0	0,0	0,0	0,3	0,0	0,0	0,0	0,8	0,0	0,0	0,0	0,8 – 2,6	0,1	0,0	0,8
BB	1,6	0,0	0,3	0,1	0,3	0,1	0,0	0,4	0,0	10,3	0,0	7,4	0,3	0,0	0,0	1,1 – 3,1	0,2	0,2	0,4
HB	0,0	0,1	0,5	0,2	0,0	0,1	0,0	0,1	0,0	0,5	0,0	0,3	0,0	0,0	0,0	0,3 – 0,8	0,1	0,0	0,3
HH	0,0	1,6	0,3	0,0	0,0	0,0	0,0	0,3	0,0	0,1	0,0	0,4	0,0	0,0	0,0	0,9 – 2,1	0,2	0,1	0,4
HE	0,0	0,0	1,8	0,0	0,0	0,1	0,6	0,7	0,0	4,4	0,0	5,1	0,2	0,1	0,0	2,4 – 6,7	0,3	0,0	0,6
MV	0,0	0,0	0,4	0,0	0,0	0,0	0,0	0,3	0,0	6,5	2,2	5,3	0,2	0,0	0,0	0,4 – 1,3	0,0	0,1	0,6
NI	0,0	0,9	2,6	0,3	0,0	0,1	0,2	1,0	0,0	17,6	17,0	8,7	0,9	0,1	0,0	3,4 – 9,5	0,6	0,5	1,3
NW	3,2	3,3	9,1	1,3	0,1	0,5	0,3	1,8	0,2	11,0	0,0	13,1	0,5	0,2	0,4	8,6 – 22,2	1,4	0,9	2,8
RP	0,0	0,0	1,8	0,0	0,0	0,1	0,0	0,4	0,0	6,9	0,0	5,1	0,1	0,2	0,0	2,0 – 4,8	0,3	0,2	0,4
SL	0,0	0,0	0,3	0,1	0,0	0,0	0,0	0,1	0,0	0,4	0,0	1,2	0,0	0,0	0,1	0,5 – 1,6	0,1	0,0	0,2
SN	3,3	0,0	0,7	0,0	0,0	0,0	1,1	0,6	0,0	1,8	0,0	4,1	0,2	0,1	0,0	1,4 – 3,7	0,2	0,2	0,5
ST	1,0	0,0	0,9	0,0	0,1	0,2	0,1	0,5	0,0	6,8	0,0	4,6	0,3	0,0	0,0	0,9 – 2,5	0,2	0,4	0,5
SH	0,0	0,0	0,5	0,0	0,0	0,0	0,1	0,4	0,1	12,5	4,0	3,9	0,3	0,0	0,0	0,9 – 3,1	0,2	0,2	1,3
TH	0,0	0,0	0,5	0,0	0,0	0,0	3,0	0,4	0,0	4,8	0,0	2,6	0,2	0,0	0,0	0,7 – 2,2	0,1	0,0	0,2
AT (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,6	0,0	0,0	0,0	0,0	0,0	0,0	0,8	0,0	0,0 – 0,0	0,0	0,0	0,0
LU (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0 – 0,0	0,0	0,0	0,0
Summe**	9,0	8,1	28,0	2,0	0,5	1,7	11,3	9,8	0,3	90,8	23,2	97,4	4,6	5,1	0,6	33,9 – 94,8	5,0	3,0	12,6



\* Erzeugungsanlagen im Ausland mit Einspeisung in das deutsche Übertragungsnetz  
 \*\* Bei der Aufsummierung der Einzelwerte können sich Rundungsabweichungen ergeben.  
 \*\*\* Das Band der Nachfrage umfasst den klassischen Stromverbrauch sowie Wärmepumpen, Elektromobilität und VNB-Verluste ohne Einsatz von DSM, Power-to-Gas / -Heat.

# Grid Development Plan 2030 (2019)


## Installed capacity by state

### Scenario C 2030



NETZ  
ENTWICKLUNGS  
PLAN STROM

C 2030 (in GW)	Braunkohle	Steinkohle	Erdgas	Kuppelgas	Öl	Abfall	Pumpspeicher	KWK < 10 MW	sonstige Konventionelle	Wind onshore	Wind offshore	Photovoltaik	Bio-masse	Lauf- und Speicherwasser	sonstige EE	Band der Nachfrage	zusätzliche Verbraucher		
																	DSM	PIG	PIH
BW	0,0	2,3	1,9	0,0	0,0	0,1	1,9	1,1	0,0	3,7	0,0	14,6	0,7	1,0	0,0	4,2 – 13,8	0,7	0,0	1,5
BY	0,0	0,0	4,7	0,0	0,0	0,2	0,8	1,1	0,0	2,6	0,0	22,4	1,2	2,4	0,1	5,3 – 16,4	0,8	0,2	1,6
BE	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,2	0,0	0,0	0,0	1,1	0,0	0,0	0,0	0,9 – 2,7	0,1	0,0	1,0
BB	1,6	0,0	0,2	0,1	0,3	0,1	0,0	0,4	0,0	10,1	0,0	6,5	0,4	0,0	0,0	1,1 – 3,3	0,2	0,2	0,5
HB	0,0	0,1	0,5	0,2	0,0	0,1	0,0	0,1	0,0	0,5	0,0	0,4	0,0	0,0	0,0	0,3 – 0,9	0,1	0,0	0,3
HH	0,0	1,6	0,3	0,0	0,0	0,0	0,0	0,3	0,0	0,1	0,0	0,6	0,0	0,0	0,0	0,9 – 2,2	0,2	0,1	0,5
HE	0,0	0,0	1,7	0,0	0,0	0,1	0,6	0,6	0,0	3,9	0,0	6,0	0,2	0,1	0,0	2,5 – 7,1	0,4	0,0	0,8
MV	0,0	0,0	0,4	0,0	0,0	0,0	0,0	0,2	0,0	6,4	2,2	4,2	0,3	0,0	0,0	0,5 – 1,5	0,0	0,1	0,7
NI	0,0	0,9	2,4	0,3	0,0	0,1	0,2	0,8	0,0	17,3	10,8	10,2	1,1	0,1	0,0	3,5 – 10,1	0,7	0,5	1,6
NW	3,2	3,3	8,4	1,3	0,1	0,5	0,3	1,5	0,2	9,8	0,0	16,0	0,7	0,2	0,4	8,9 – 23,3	1,7	0,9	3,9
RP	0,0	0,0	1,7	0,0	0,0	0,1	0,0	0,4	0,0	6,1	0,0	5,6	0,1	0,2	0,0	2,0 – 5,1	0,4	0,2	0,5
SL	0,0	0,0	0,3	0,1	0,0	0,0	0,0	0,1	0,0	0,4	0,0	1,3	0,0	0,0	0,1	0,5 – 1,6	0,1	0,0	0,3
SN	3,3	0,0	0,6	0,0	0,0	0,0	1,1	0,5	0,0	1,8	0,0	4,4	0,3	0,1	0,0	1,4 – 4,0	0,2	0,2	0,6
ST	1,0	0,0	0,8	0,0	0,1	0,2	0,1	0,4	0,0	6,7	0,0	4,4	0,4	0,0	0,0	1,0 – 2,7	0,2	0,4	0,6
SH	0,0	0,0	0,5	0,0	0,0	0,0	0,1	0,3	0,1	12,3	4,0	4,0	0,4	0,0	0,0	0,9 – 3,3	0,2	0,2	1,4
TH	0,0	0,0	0,5	0,0	0,0	0,0	3,0	0,3	0,0	3,7	0,0	2,8	0,2	0,0	0,0	0,7 – 2,4	0,1	0,0	0,3
AT (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,6	0,0	0,0	0,0	0,0	0,0	0,0	0,8	0,0	0,0 – 0,0	0,0	0,0	0,0
LU (DE)*	0,0	0,0	0,0	0,0	0,0	0,0	1,3	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0	0,0 – 0,0	0,0	0,0	0,0
Summe**	9,0	8,1	26,0	2,0	0,5	1,7	11,0	8,3	0,3	85,5	17,0	104,5	6,0	5,1	0,6	35,1 – 100,2	6,0	3,0	16,1




- \* Erzeugungsanlagen im Ausland mit Einspeisung in das deutsche Übertragungsnetz
- \*\* Bei der Aufsummierung der Einzelwerte können sich Rundungsabweichungen ergeben.
- \*\*\* Das Band der Nachfrage umfasst den klassischen Stromverbrauch sowie Wärmepumpen, Elektromobilität und VNB-Verluste ohne Einsatz von DSM, Power-to-Gas / -Heat.





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Exit from coal fired power-generation



# Grid Development Plan 2030 (2019)

## Results of the commission on growth and structural change (WSB-commission) and assumed capacities in the GDP 2030 (2019)




NETZ  
ENTWICKLUNGS  
PLAN STROM

- **Recommendations of the WSB-commission on capacities of coal-fired power plants:**

- **17 GW capacity of coal in 2030**  
(8 GW hard coal , 9 GW lignite)
- **0-<17 GW in 2035**

- **Capacities in the GDP scenarios**

- **A 2030: 22,9 GW**  
(13,5 GW hard coal 9,4 GW lignite)
- **B 2030: 19,1 GW**  
(9,8 GW hard coal 9,3 GW lignite)
- **C 2030: 17,1 GW**  
(8,1 GW hard coal, 9,0 GW lignite)
- **B 2035: 17,1 GW**  
(8,1 GW hard coal, 9,0 GW lignite)



Rounded numbers

→ **Conclusion:**

- Capacities in **B 2030** almost compatible with recommendations by WSB-commission
- Capacities in **C 2030** almost identical to recommendations by WSB-commission
- Capacities in **B 2035** are at the upper bound of recommended bandwidth.
- The sensitivity calculation in the second draft „**B 2035 – Exit from coal**“ confirms the sustainability of grid measures even in the case of 0 GW coal.



# Grid Development Plan 2030 (2019)

## Sensitivity calculation „B 2035 – Exit from coal“



NETZ  
ENTWICKLUNGS  
PLAN STROM

- The sensitivity calculation „B 2035 – Exit from coal“ was conducted to make sure that all grid measures identified for 2030 and 2035 are necessary in the case of a complete exit from coal-fired power generation.
- The calculation is based on scenario B 2035. Analogously to the GDP, reductions in coal generation by cogenerating plants were substituted by gas based innovative cogeneration facilities (+1.1 GW).

### Results of the market-simulation:

- Net exports decline in comparison to B 2035 from 35.9 to 19 TWh: Less exports to southern and western Europe, more imports from northern and eastern Europe.
- + 24 TWh additional generation from gas power plants
- Dumped Energy declines from 6.1 to 4.4 TWh → better integration of renewables
- CO<sub>2</sub>-limit is reached without additional CO<sub>2</sub>-pricing (96.1 instead of 127 mio. t)


### Results of the grid-analysis:

- Grid measures identified in B 2035 are necessary even without power generation from coal → identified measures are robust
- Redispatch with the measures of B 2035 increases from 2.6 to 3.3 TWh



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Offshore Grid Development



# Grid Development Plan 2030 (2019)

## Determining the expansion requirements of the offshore-grid



NETZ  
ENTWICKLUNGS  
PLAN STROM

- The determinations previously laid down in the **O-GDP** have, due to a change in the law, partly been moved to **GDP** and partly to the Area Development Plan (Flächenentwicklungsplan (**FEP**)), compiled by the Bundesamt für Seeschifffahrt und Hydrographie (BSH).
- The GDP and FEP are a coordinated planning tool and together form the basis for the regional planning of the coastal states.
- The current Scenario Framework differs from the current draft of the FEP as well as from the EEG in expecting an expansion of offshore wind up to **17 GW** in Scenario **B 2030 and C 2030**, and of **20 GW** in Scenario **A 2030** as well as **23.2 GW** in Scenario **B 2035**. This expansion happens almost exclusively in the North Sea.


Gebiet	B 2030 / C 2030	A 2030	B 2035
Nordsee	14,8 GW	17,8 GW	21,0 GW
Ostsee	2,2 GW	2,2 GW	2,2 GW
<b>Gesamt</b>	<b>17,0 GW</b>	<b>20,0 GW</b>	<b>23,2 GW</b>

# Grid Development Plan 2030 (2019)

## From the O-GDP to the FEP



NETZ  
ENTWICKLUNGS  
PLAN STROM



# Grid Development Plan 2030 (2019)

## Start offshore grid North Sea and Baltic Sea



NETZ  
ENTWICKLUNGS  
PLAN STROM

### Transmission capacities:

Start offshore grid (total)

11,7 GW

→ North Sea


9,8 GW

→ Baltic Sea

1,9 GW

Investment:

about 8 billion €



# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenarios B 2030 and C 2030




NETZ  
ENTWICKLUNGS  
PLAN STROM

**Transmission capacity:  
expansion grid (North Sea) 5,8 GW**

**Total length of the  
expansion grid (North Sea) 1.756 km**

**Approximated investment costs  
expansion grid (North Sea) 9 billion €**



# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenarios B 2030 and C 2030



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Projekt	Bezeichnung der Maßnahme	Netzverknüpfungspunkt	Beginn der Umsetzung	Geplante Fertigstellung
NOR-3-2	HGÜ-Verbindung NOR-3-2 (DolWin4)	Hanekenfähr	2023	2028
NOR-6-3	HGÜ-Verbindung NOR-6-3 (BorWin4)	Hanekenfähr	2024	2029
NOR-7-2	HGÜ-Verbindung NOR-7-2 (BorWin6)	Büttel	2022	2027
NOR-9-1	HGÜ-Verbindung NOR-9-1 (BalWin1)	Unterweser	2024	2029
NOR-9-2	HGÜ-Verbindung NOR-9-2 (BalWin2)	Suchraum Gemeinden Ibbenbüren / Mettingen / Westerkappeln	nach 2025	nach 2030
NOR-10-2	HGÜ-Verbindung NOR-10-2 (BalWin3)	Heide / West	2025	2030



# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenario A 2030




NETZ  
ENTWICKLUNGS  
PLAN STROM

**Transmission capacity:  
expansion grid (North Sea) 9,2 GW**

**Total length of the  
expansion grid (North Sea) 2.751 km**

**Approximated investment costs  
expansion grid (North Sea) 15 billion €**





# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenario A 2030



NETZ  
ENTWICKLUNGS  
PLAN STROM

Projekt	Bezeichnung der Maßnahme	Netzverknüpfungspunkt	Beginn der Umsetzung	Geplante Fertigstellung
NOR-3-2	HGÜ-Verbindung NOR-3-2 (DolWin4)	Hanekenfähr	2023	2028
NOR-6-3	HGÜ-Verbindung NOR-6-3 (BorWin4)	Hanekenfähr	2024	2029
NOR-7-2	HGÜ-Verbindung NOR-7-2 (BorWin6)	Büttel	2022	2027
NOR-9-1	HGÜ-Verbindung NOR-9-1 (BalWin1)	Unterweser	2023	2028
NOR-9-2	HGÜ-Verbindung NOR-9-2 (BalWin2)	Suchraum Gemeinden Ibbenbüren / Mettingen / Westerkappeln	nach 2025	nach 2030
NOR-10-1	HGÜ-Verbindung NOR-10-1 (BalWin4)	Suchraum Gemeinden Ibbenbüren / Mettingen / Westerkappeln	nach 2025	nach 2030
NOR-10-2	HGÜ-Verbindung NOR-10-2 (BalWin3)	Heide / West	2024	2029
NOR-12-1	HGÜ-Verbindung NOR-12-1 (LanWin1)	Wilhelmshaven 2	2025	2030
NOR-12-2	HGÜ-Verbindung NOR-12-2 (LanWin2)	Wehrendorf	nach 2025	nach 2030

# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenario B 2035




NETZ  
ENTWICKLUNGS  
PLAN STROM

**Transmission capacity:  
expansion grid (North Sea) 11,5 GW**

**Total length of the  
expansion grid (North Sea) 3.271 km**

**Approximated investment costs  
expansion grid (North Sea) 18 billion €**



# Grid Development Plan 2030 (2019)

## Offshore expansion grid North Sea

### Scenario B 2035



NETZ  
ENTWICKLUNGS  
PLAN STROM

Projekt	Bezeichnung der Maßnahme	Netzverknüpfungspunkt	Beginn der Umsetzung	Geplante Fertigstellung
NOR-3-2	HGÜ-Verbindung NOR-3-2 (DoWin4)	Hanekenfähr	2023	2028
NOR-6-3	HGÜ-Verbindung NOR-6-3 (BorWin4)	Hanekenfähr	2024	2029
NOR-7-2	HGÜ-Verbindung NOR-7-2 (BorWin6)	Büttel	2022	2027
NOR-9-1	HGÜ-Verbindung NOR-9-1 (BalWin1)	Unterweser	2024	2029
NOR-9-2	HGÜ-Verbindung NOR-9-2 (BalWin2)	Suchraum Gemeinden Ibbenbüren / Mettingen / Westerkappeln	nach 2025	nach 2030
NOR-10-1	HGÜ-Verbindung NOR-10-1 (BalWin4)	Suchraum Gemeinden Ibbenbüren / Mettingen / Westerkappeln	nach 2025	nach 2030
NOR-10-2	HGÜ-Verbindung NOR-10-2 (BalWin3)	Heide / West	2025	2030
NOR-11-1	HGÜ-Verbindung NOR-11-1 (LanWin3)	Wilhelmshaven 2	2029	2034
NOR-11-2	HGÜ-Verbindung NOR-11-2 (LanWin4)	Unterweser	2030	2035
NOR-12-1	HGÜ-Verbindung NOR-12-1 (LanWin1)	Wilhelmshaven 2	2027	2032
NOR-12-2	HGÜ-Verbindung NOR-12-2 (LanWin2)	Wehrendorf	nach 2025	nach 2030

# Grid Development Plan 2030 (2019)


## Offshore expansion grid Baltic Sea

### Scenarios A 2030, B 2030, C 2030 und B 2035



NETZ  
ENTWICKLUNGS  
PLAN STROM

<b>Transmission capacity: expansion grid (Baltic Sea)</b>	<b>0,6 GW</b>
<b>Total length of the expansion grid (Baltic Sea)</b>	<b>150 km</b>
<b>Approximated investment costs expansion grid (Baltic Sea)</b>	<b>1 billion €</b>



# Grid Development Plan 2030 (2019)

## Offshore expansion grid Baltic Sea

### Scenarios A 2030, B 2030, C 2030 und B 2035



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Projekt	Bezeichnung der Maßnahme	Netzverknüpfungspunkt	Beginn der Umsetzung	Geplante Fertigstellung
OST-1-4	AC-Verbindung OST-1-4	Suchraum Gemeinden Lubmin / Brünzow / Wusterhusen / Kemnitz	2023	2026
OST-7-1	AC-Verbindung OST-7-1 (nördlich Warnemünde)	Suchraum Gemeinde Papendorf	2026	2029


# Grid Development Plan 2030 (2019)

## Approximated investment costs offshore grid



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Abbildung 32: Schätzung des Investitionsvolumens in Abhängigkeit der Szenarien des NEP 2030 (2019)



# Grid Development Plan 2030 (2019)

## Sensitivity calculation for the Baltic Sea




- In a **sensitivity calculation** 50Hertz evaluated the impact of an increase of 1 GW offshore generation in the territorial waters of the Baltic Sea in easily accessible areas.
- The results show that an increased feed-in from offshore wind in the Baltic Sea compared to the current Scenario Framework **does not necessitate further onshore grid measures** beyond the measures already identified.
- This implies **additional flexibility** in the political goals for power generation from offshore wind in a bandwidth of **17 to 20 GW**.



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Results of the market simulation





# Grid Development Plan 2030 (2019)

## Results of the market simulation (I)



- The market simulation of the GDP 2030 (2019) reflects the **ongoing transformation of the energy sector** towards the integration of renewable energy.
- **Wind (on- and offshore) is the energy source with the highest share of overall power generation** in all scenarios. With 55% in 2025 up to 70% in 2035, Germany exhibits a large share of renewable generation compared to its European neighbours.
- The goal of **65% renewable energy of gross electricity consumption** as formulated in the **coalition agreement** is reached in **all scenarios for 2030** – and even slightly exceeded (67%-68%). In Scenario B 2035 the share of renewables as fraction of gross electricity consumption increases to 73.7 %.
- Increased **flexibility from cogeneration facilities** and demand side flexibility support the integration of fluctuating renewables. However, it can be expected that generation from renewables will be capped more frequently as a result of market outcomes, because it cannot be integrated.
- In the **scenarios with the target year 2030** the amount of **Dumped Energy** (= generation without corresponding demand) increases significantly compared to the GDP 2030 (2017), but remains low overall (2 - 4.5 TWh) in comparison to the total power generation from renewables.

# Grid Development Plan 2030 (2019)

## Results of the market simulation (II)




- **Full-load hours of thermal power generation technologies significantly differ between the scenarios for all energy sources.** The reasons for the differences are among others the full flexibilization of thermal power generation in scenario C 2030 as well as additional CO<sub>2</sub> prices in the scenarios A 2030 and B 2035. The full-load hours of lignite power plants are significantly below those of the GDP 2030 (2017) in all scenarios.
- **An additional CO<sub>2</sub> price** in Germany for reaching the limits set in the Scenario Framework is necessary **only in scenario A 2030 (+10 €/t CO<sub>2</sub>) and B 2035 (+28 €/t CO<sub>2</sub>)**. In all other scenarios the limit for emissions is reached without additions to the European CO<sub>2</sub> price.
- **In all scenarios a strong inner-German difference in power generation can be observed.** While power generation, mostly from renewables, in Northern and Eastern Germany is almost twice as high as local demand, Southern and Western Germany exhibit a generation deficit. Between a quarter and half of yearly demand must be imported from other Federal States or other countries.

# Grid Development Plan 2030 (2019)

## Overview of the market model of the electricity market



NETZ  
ENTWICKLUNGS  
PLAN STROM




Quelle: Pöyry Management Consulting/ Übertragungsnetzbetreiber

# Grid Development Plan 2030 (2019)

## Energy balance B 2030: North/South Divide



NETZ  
ENTWICKLUNGS  
PLAN STROM



### Generation surplus in Northern Germany:

Power generation in Northern and Eastern German states is almost double the local demand.

### Generation deficit in Southern Germany:

Between a quarter and half of energy demand in Southern States is satisfied by imports from other states or countries.

The overall trend is the same in all scenarios, only values differ slightly

# Grid Development Plan 2030 (2019)


## Peak capping and Dumped Energy



NETZ  
ENTWICKLUNGS  
PLAN STROM

- Significant amounts of Dumped Energy (generation surplus from renewables without corresponding demand) for the first time
- Overall amount is still low compared to overall generation from renewables
- The sum of peak capping and Dumped Energy amounts to just 1.5 - 2.2% of total generation from renewables in 2030 and 2.4 % in 2035

Theoretically this implies a potential for local use of surplus energy (e.g. by PtX)




# Grid Development Plan 2030 (2019)


Trade: Net power exporter in A 2030 and B 2030



NETZ  
ENTWICKLUNGS  
PLAN STROM



**A 2030**



**B 2030**




# Grid Development Plan 2030 (2019)


Trade: Net export significantly higher in C 2030 compared to B 2035



NETZ  
ENTWICKLUNGS  
PLAN STROM



**B 2035**



**C 2030**

# Grid Development Plan 2030 (2019)

## Power plant use and CO<sub>2</sub>-emissions: Additional CO<sub>2</sub> price only in A 2030 and B 2035



NETZ  
ENTWICKLUNGS  
PLAN STROM

■ Szenario B 2030


■ Szenario C 2030

■ Szenario B 2035


■ Szenario B 2025

■ Szenario A 2030

Abbildung 47: CO<sub>2</sub>-Emissionen in der Stromerzeugung in Deutschland in den Szenarien des NEP 2030 (2019)



Quelle: Übertragungsnetzbetreiber




	Braun- kohle	Stein- kohle	Erdgas	Kuppel- gas	Öl
B 2025	6.827	5.942	2.624	3.491	883
A 2030	4.987	4.806	2.421	3.491	876
B 2030	6.292	5.842	2.414	3.389	910
C 2030	6.751	6.461	1.582	4.239	3
B 2035	2.630	2.699	2.054	3.391	697





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Results of the grid analyses



# Grid Development Plan 2030 (2019)

## Key results of the grid analyses (I)



- Due to the new definition of the starting grid (measures become part of the starting grid at the beginning of the plan approval procedures instead of at the end), **the starting grid grew by about one third compared to the GDP 2030 (2017).**
- Apart from the ad-hoc measures already approved by the Federal Network Agency (BNetzA) after the GDP 2030 (2017), **further redispatch-lowering measures were identified.** Additionally, the use of grid booster pilots was analysed.
- Further phase-shifting transformers were included in the target grids for 2030 and 2035 to optimise power flows in the AC grid and to thereby **reduce the need for grid development and expansion.**

# Grid Development Plan 2030 (2019)

## Key results of the grid analyses (II)



- For the first time, the TSOs implicitly **accounted for the potential of future innovative technologies** (for example modern system controls, grid booster). To account for this potential, bottlenecks in the scenarios for 2030 and 2035 were not fully eliminated with grid enhancement and grid expansion measures.
- In addition to 4 TWh of peak capping, a **redispatch volume of 1.1 TWh in A 2030, 1.9 TWh in B 2030, and 2.6 TWh in C 2030 and B 2035** remain in the proposed grids.
- To integrate 65 % of renewables into the energy system the TSOs continue their approach of **optimising and developing the existing AC grid, adding devices to steer the power-flow, as well as new DC connections** to handle the north-south electricity transport needs.

# Grid Development Plan 2030 (2019)

## Key results of the grid analyses (III)



- Due to the assumed innovations of the grid and markets, **the development and expansion needs of the GDP 2030 (2019) remain constant compared to the GDP 2030 (2017).**
- The overall length of identified connections in scenario B 2030 (2019), including additional DC connections, are **slightly below those identified in Scenario B 2030 (2017)**, where the focus was exclusively on expanding the AC grid.
- **All measures of the Federal Requirements Plan** (Bundesbedarfsplan) as well as the additional measures confirmed by the BNetzA in the NEP 2030 (2017) **are necessary** in all scenarios for 2030 as well as 2035.
- The **necessity of these measures**, which are needed for an adequate grid in the face of rising transport needs, **is once more confirmed in the GDP 2030 (2019).**

# Grid Development Plan 2030 (2019)

## Key results of the grid analyses (short)



- **All measures of the Federal Requirements Plan (Bundesbedarfsplan) as well as the additional measures confirmed by the BNetzA in the NEP 2030 (2017) are necessary** in all scenarios for 2030 as well as 2035. They are not sufficient, however, for an adequate grid.
- For the first time, the TSOs implicitly **accounted for the potential of future innovative technologies** (for example modern system controls, grid booster). To account for this potential, bottlenecks in the scenarios for 2030 and 2035 were not fully eliminated with grid enhancement and grid expansion measures.
- In addition to 4 TWh of peak capping, a **redispatch volume of 1.1 TWh in A 2030, 1.9 TWh in B 2030, and 2.6 TWh in C 2030 and B 2035** remain in the proposed grids.
- Due to the assumed innovations of the grid and markets, **the development and expansion needs of the GDP 2030 (2019) remain constant compared to the GDP 2030 (2017)**, even though transport needs are higher due to more renewables in the system.


# Grid Development Plan 2030 (2019)

## Redispatch and peak capping: room for innovation



NETZ  
ENTWICKLUNGS  
PLAN STROM

Spitzenkappung und verbleibender Redispatch mit den Zielnetzen 2030 und 2035




Quelle: Übertragungsnetzbetreiber

# Grid Development Plan 2030 (2019)

TSO's factor in diverse innovations to minimize grid-development and expansion needs



NETZ  
ENTWICKLUNGS  
PLAN STROM







## Starting grid GDP 2030 (2019)

New definition of starting grid:

- Up to now: current grid, EnLAG measures and measures with planning permission as well as measures currently being built.
- New: Additional measures for which the plan approval procedure started.

Total amount: 2,630 km  
about 700 km more than in the GDP 2030 (2017)

Existing AC lines with new OHL conductors	130 km
New AC lines in existing routes	1,650 km
New AC lines in new routes	600 km
New DC lines:	250 km
Estimated investments:	EUR 12,5 billion


# Grid Development Plan 2030 (2019)

## Overload in the starting grid including interconnectors




NETZ  
ENTWICKLUNGS  
PLAN STROM

Maximum load per circuit in the case of failure of one grid element.  
So called „(n-1) –case“.



Maximum utilisation of line capacity:  
More than 300% on some lines



Frequency of overloading:  
Over 1000 hours on some lines


# Grid Development Plan 2030 (2019)

## Overload in the confirmed grid from the Federal Requirements Plan including interconnectors




NETZ  
ENTWICKLUNGS  
PLAN STROM

Maximum load per circuit in the case of failure of one grid element.  
So called „(n-1) –case“:



Quelle: Übertragungsnetzbetreiber

Maximum utilisation of line capacity:  
More than 200% on some lines



Quelle: Übertragungsnetzbetreiber

Frequency of overloading:  
Over 1000 hours on some lines





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

## Scenario B 2025

Confirmation of facilities for grid optimization and avoidance of redispatch:

- Confirmed ad hoc measures from GDP 2030 (2017) – 9 measures, including one power line (P310)
- Further phase shifters from GDP 2030 (2019) – 4 measures, one per control area.

- Grid booster pilots (purple)

Depicted on the map as well:

- Further facilities for load flow management from the 2030 and 2035 scenarios (grey)


# Grid Development Plan 2030 (2019)

## Scenario B 2025: Ad hoc measures significantly decrease redispatch volume



NETZ  
ENTWICKLUNGS  
PLAN STROM

Abbildung 58: Redispatch-Bewertung der untersuchten Netztopologien im Szenario B 2025







NETZ  
ENTWICKLUNGS  
PLAN STROM

## Scenario A 2030 incl. starting grid

**Expansion of DC connections in Germany** 3,780 km

- Transport capacity 12 GW
- Interconnectors to BEL, DNK, NOR, GBR und SWE 520 km


**Expansion of AC grid** 1,030 km

**DC/AC grid enhancement** 6,670 km

- Thereof new OHL on existing pylons 2,280 km

**Estimated investments**  
if all DC lines (except DC2) are built as underground cables EUR 61 billion





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

## Scenario B 2030 incl. starting grid

**Expansion of DC connections in Germany** 3,780 km

- Transport capacity 12 GW
- Interconnectors to BEL, DNK, NOR, GBR und SWE 520 km

**Expansion of AC grid** 1,030 km

**DC/AC grid enhancement** 6,710 km

- Thereof new OHL on existing pylons 2,190 km

**Estimated investments**  
if all DC lines (except DC2) are built as underground cables EUR 61 billion





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

## Scenario C 2030 incl. starting grid

**Expansion of DC connections in Germany** 3,780 km

- Transport capacity 12 GW
- Interconnectors to BEL, DNK, NOR, GBR und SWE 520 km

**Expansion of AC grid** 1,130 km

**DC/AC grid development** 7,180 km

- Thereof new OHL on existing pylons 2,420 km

**Estimated investments** EUR  
if all DC lines (except DC2) are built as underground cables 62.5 billion





NETZ  
ENTWICKLUNGS  
PLAN **STROM**

## Scenario B 2035 incl. starting grid

**Expansion of DC connections in Germany** 4,080 km

- Transport capacity: 14 GW
- Interconnectors to BEL, DNK, NOR, GBR und SWE 520 km

**Expansion of AC grid** 1,140 km

**DC/AC grid development** 7,490 km

- Thereof new OHL on existing pylons 2,110 km

**Estimated investments**  
if all DC lines (except DC2) are built as underground cables **EUR 68 billion**

# Grid Development Plan 2030 (2019)

Need for grid enhancement and expansion in 2030  
4,350 to 4,950 km in addition to FRP (BBP)



NETZ  
ENTWICKLUNGS  
PLAN STROM

Angaben in km	AC-Verstärkung		DC-Verstärkung		AC-Neubau	DC-Neubau	Summe
	Zu- / Umbeseilung	Neubau in Bestandstrasse	Zu- / Umbeseilung	Neubau in Bestandstrasse			
<b>Startnetz</b>	130	1.650	0	0	600	250	<b>2.630</b>
<b>Zubaunetz</b>							
<b>A 2030</b>	1.850	2.700	300	40	430	3.530	<b>8.740</b>
<b>B 2030</b>	1.760	2.830	300	40	430	3.530	<b>8.890</b>
<b>C 2030</b>	1.990	3.070	300	40	530	3.530	<b>9.460</b>
<b>B 2035</b>	1.750	3.030	300	580	550	3.830	<b>10.040</b>
<b>Start- und Zubaunetz</b>							
<b>A 2030</b>	1.980	4.350	300	40	1.030	3.780	<b>11.480</b>
<b>B 2030</b>	1.890	4.480	300	40	1.030	3.780	<b>11.520</b>
<b>C 2030</b>	2.120	4.720	300	40	1.130	3.780	<b>12.090</b>
<b>B 2035</b>	1.880	4.680	300	580	1.150	4.080	<b>12.670</b>

**Measures  
in addition  
to FRP  
(BBP)**

**4,350 km**

**4,400 km**

**4,950 km**

# Grid Development Plan 2030 (2019)

## Estimated investments including full cabling of DC connections and DC interconnectors



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

Angaben in Mrd. EUR (gerundet)	A 2030	B 2030	C 2030	B 2035
DC-Zubaunetz	28,5	28,5	28,5	33,5
DC-Startnetz	1,5	1,5	1,5	1,5
AC-Zubaunetz*	20,0	20,0	21,5	22,0
AC-Startnetz	11,0	11,0	11,0	11,0
<b>Summe</b>	<b>61,0</b>	<b>61,0</b>	<b>62,5</b>	<b>68,0</b>

\* inkl. Anlagen zur Blindleistungskompensation

# Grid Development Plan 2030 (2019)

## Estimated investments onshore:

### Increase from GDP 2030 (2017) to GDP 2030 (2019)



NETZ  
ENTWICKLUNGS  
PLAN STROM


#### Three main reasons:

1. Adjustment of standard costs
  - Update of cost base
  - Consideration of TSO experiences
  - Consideration of costs for planning and permission procedures
2. New configuration
  - More DC underground cables instead of AC overhead lines → acceptance
  - Additional ad hoc measures
3. Consideration of additional reactive power facilities

#### Putting the costs into perspective:

- Investments are made over the years up to 2030/2035
- Projects are depreciated over a period of up to 40 years

Geschätzte Investitionskosten im NEP 2030 (2019)



# Grid Development Plan 2030 (2019)

## Use of underground cables (DC)



- In 2016 the legislator introduced the rule that **underground cables have to take precedence** over overhead lines for four of the five **DC projects** of the Federal Requirements Plan (Bundesbedarfsplan). Accordingly, the costs for these DC projects (DC1, and DC3-DC5) as well as the newly identified DC connections (DC20, DC21, DC23, DC25) are calculated for the use of underground cables.
- Generally the **additional costs for underground cables** as compared to overhead lines for both DC and AC cables strongly depend on local factors like soil structure.
- For DC cables the standard costs in the GDP 2030 (2019) were estimated to be 6 million € per km for one connection with 1 x 2 GW and 12 million € per km for 2 x 2 GW.
- This cost estimate takes into account **experiences of the TSOs** with the first AC underground cable pilots as well as HVDC underground cables like offshore connections and undersea cables.

# Grid Development Plan 2030 (2019)

## Use of underground cables (AC)



- In the GDP **AC lines** are generally assumed to be realized as overhead lines. The costs for partial underground cabling were taken into account only if the projects are defined as **pilot projects for partial underground cabling** according to § 2 EnLAG or § 4 BBPlG. Further details can be found in the project profiles of the relevant projects.
- Generally, the **additional costs for underground cables** as compared to overhead lines for both DC and AC cables strongly depend on local factors like soil structure.
- For **AC projects with partial underground cabling**, the costs for the underground cable sections are estimated at **11.4 million € per km for the 380 kV underground cable**. This includes the necessary cable transition facilities and at the same time assumes higher acceptance.



# Grid Development Plan 2030 (2019)

## Cost-benefit-analyses for interconnectors



NETZ  
ENTWICKLUNGS  
PLAN STROM

- According to the demand by the Federal Network Agency (BNetzA) the TSOs conducted cost benefit analyses (CBA) for the eight additional interconnectors that are not yet in the FRP (BBP) – based on Scenario B 2035.
- The procedure for conducting the CBAs largely followed that of the TYNDP 2018. Further details can be found in chapter 5.4 of the GDP.
- The results of the CBAs can be found in the project profiles in the appendix to the GDP.

Tabelle 24: Übersicht über die ausgewerteten Indikatoren im Rahmen der Kosten-Nutzen-Analyse

Indikator (gemäß ENTSO-E Bezeichnung)	Berechnungsmethode bzw. Ursprung	Einheit
B1. Socio-economic welfare	Marksimulation und Redispatch	€/Jahr
B2. Variation in CO <sub>2</sub> emissions	Marksimulation und Redispatch	Tonnen/Jahr
B3. RES integration	Marksimulation und Redispatch	MW bzw. MWh/Jahr
B4. Societal well-being as result of RES integration and change in CO <sub>2</sub> emissions	Marksimulation und Redispatch	€/Jahr
B5. Variation in grid losses	Lastflussberechnung	MWh/Jahr
C1. Capital Expenditure (CAPEX)	ÜNB Info	€
C2. Operational Expenditure (OPEX)	ÜNB Info	€/Jahr

# Grid Development Plan 2030 (2019)

## Analysis of the system stability



NETZ  
ENTWICKLUNGS  
PLAN STROM

- Based on Scenario B 2035 the TSOs conducted system stability analyses
- Frequency stability, angle stability (transient stability), and voltage stability were analysed.
- A short version of the analysis can be found in Chapter 5.5 of the GDP, a separate longer version is as a separate document on [www.netzentwicklungsplan.de](http://www.netzentwicklungsplan.de) (in German)
- The analysis shows a considerable need for reactive power compensation systems to cover stationary and controllable requirements with a total installed capacity of at least 38.1 to 74.3 Gvar (127 to 248 facilities with 300 MVA each)

Zubaubedarf [Gvar]	TenneT	Transnet BW	Amprion	50Hertz	Deutschland
Stationär spannungshebend	3,0 – 10,4	1,5 – 2,3	1,6 – 8,9	5,1 – 9,4	11,2 – 31,1
Stationär spannungssenkend	0,0 – 2,6	0,3 – 1,4	1,2 – 5,2	2,2 – 6,5	4,3 – 14,8
Regelbar	6,2 – 7,7	1,1 – 1,8	4,2 – 5,8	11,1 – 13,1	22,6 – 28,4
<b>Summe</b>	<b>9,2 – 20,7</b>	<b>2,9 – 5,5</b>	<b>7,0 – 19,9</b>	<b>18,4 – 29,1</b>	<b>38,1 – 74,3</b>



# Grid Development Plan 2030 (2019)

## Analysis of the system stability




NETZ  
ENTWICKLUNGS  
PLAN STROM

Why does the demand for reactive power compensation rise so steeply?

- One reason is the decommission of conventional power plants (thus they cannot provide reactive power any more)
- Second reason is the higher utilization of existing transmission lines – leading to an overproportional increase of reactive power compensation

→ Side effect of  
NOVA + innovations

Abbildung 8: Blindleistungsbedarf einer 100 km langen 380-kV-Freileitung



# Grid Development Plan 2030 (2019)

## Conclusion (I)

### Approved Scenario Framework of the Federal Network Agency

- Challenging framework (65 % renewable, CEP, accounting for climate protection plan, flexible demand-side) means a chance to implement innovations in the market and grid-models.

### Ambitious approach of the TSOs

#### Use of grid expansion reducing measures

Already in  
market  
model

(i.e. peak  
capping)

Supplemented with assumptions about the grid:

Combination of

**Proven instruments in line with the planning guidelines**  
(i.e. NOVA, improved thermal monitoring of overhead lines)

with the use of innovative technologies in grid planning and grid control. (i.e. load flow management, 4000 A, km-optimised combination of AC and DC, no elimination of bottlenecks → leaves room for future developments)

**TSOs introduce an ambitious concept and count on the development of all actors of the energy transition**

# Grid Development Plan 2030 (2019)

## Conclusion (II)




### Results of the GDP 2030 (2019):

- Ambitious goals for renewable integration (>65% 2030) **can be integrated with similar amount of line km** as that of the GDP 2030 (2017)
  - **Combination of AC and DC** (+ 4 GW HVDC in 2030, + 2 further GW HVDC in 2035) enable the **efficient integration of renewable energy** into the grid, are robust with respect to a further rising share of renewables and are **open to new technological developments**.
  - **The development** of market incentives/business models and technological innovations by diverse players of the energy transition is necessary to make the assumptions made by the TSOs a reality.
  - The rising **need for reactive power compensation systems** shows: besides the grid enhancement and expansion, controllability and stability of the grid play an increasingly important role.
- **GDP 2030 (2019) is an adequate basis for the Federal Requirements Plan (Bundesbedarfsplan)**



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

# Backup




# Grid Development Plan 2030 (2019)

## Share of conventional and renewable generation as fraction of overall power generation



NETZ  
ENTWICKLUNGS  
PLAN STROM



\*Länder mit gemeinsamer Grenze zu Deutschland




# Grid Development Plan 2030 (2019)

## Cogeneration by primary energy source GDP 2030



NETZ  
ENTWICKLUNGS  
PLAN **STROM**



# Grid Development Plan 2030 (2019)

## Renewable energy as share of gross power consumption



NETZ  
ENTWICKLUNGS  
PLAN **STROM**

